



Technical drawing of a square foundation (Fig. 10.10). The drawing shows a cross-section of the foundation with dimensions and reinforcement details. The overall dimensions are 900 mm by 900 mm. The foundation is 30 mm thick. The reinforcement consists of 10 bars (Ø10) arranged in a grid. The distance between the bars is 600 mm. The drawing also shows the reinforcement layout for the top and bottom of the foundation.

* Sablīvēt pēc Standarta Proktora blīvuma skalas (SPD) < 98%

Nr.	Detaja	Apraksts	Daudzums, gab
1	Lūkas pārsedze (LVS EN 124-2), B125 klase	Atvērums 632x632 mm	1
2	Skrūves ar paplākšņiem	Pieskrūvēt lūkas pārsedzes rāmi pie atbalsta gredzena	9
3	Polimēra atbalsta gredzens	Uzstādā uz akas sienām	1
4	Radbox stāva komplekts	h=500 mm	8

1. Šis risinājums ir paredzēts izbūves zonā ar maksimālo slodzes klasi B125.
2. Radbox akas izbūve jāveic saskaņā ar LVS EN 13598-2 standarta prasībām.
3. Radbox aku iespējams aprīkot ar 12 mm biezu pamatni, pieskrūvētu pie sienām (pamatne nenodrošina hermētiskumu).
4. Pēc pieprasījuma ir pieejami kabelu aizsargcauruļi balsti, kas uzstādāmi pie akas sienām.

Šis rasējums ir SIA Evopipes intelektuālais īpašums.



FAILA NOSAUKUMS:

LAPA: 1 NO1

LAPAS FORMĀTS: @ A4

MĚROGS:
BEZ MĚROGA

STADIJA:
TIPVEIDA RASĒJUMS