



**BUREAU
VERITAS**

SIA „Bureau Veritas Latvia”
Duntes street 17a, Riga, LV-1005, Latvia

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Nr. 19/047

This certificate applies to the product:

Corrugated single wall flexible pipes made of polyethylene (PE) material built-in ground for the protection of cables with nominal size **DN/OD 50 mm**, nominal mechanical strength **450 (N)** and impact resistance class **L**

EVOCAB FLEX

produced in the manufacturing plant

SIA ”EVOPIPES”

Langervaldes street 2a, Jelgava, LV-3002, Latvia

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in standards

**LVS EN 61386-1:2018 „Conduit systems for cable management.
Part 1: General requirements (IEC 61386-1:2008)”**

and

**LVS EN 61386-24:2011 „Conduit systems for cable management.
Part 24: Particular requirements - Conduit systems buried underground (IEC 61386-24:2004)”**

under system „1+”, based on initial assessment and approval of the factory production control and product type initial testing with continuous surveillance including assessment and evaluation of factory production control and type testing, the performance set out in this certificate are applied and

product fulfills all the prescribed requirements set out above.

This certificate was first issued on **14/06/2019** and will remain valid till **13/06/2022** as long as product, standards, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body.

To check the validity date of this certificate, please call +371 67323246.

Further clarification regarding the scope of this certificate and the applicability of the system requirements may be obtained by consulting to Bureau Veritas Latvia.

Certificate issued:

Riga, 14/06/2019

Version: 1

SIA „Bureau Veritas Latvia”
Member of the Board



Iveta Lazdiņa